

UDT-A-01
May 19/06

specially gapped and wound device; EI core, M-19 steel - as per Jensen's recipe
60 Hz mains; 40t Primary, 2@60t Secondary, 15t Feedback; 22AWG wire

MEASURING INSTRUMENTS:

Tektronics TDS5034B digital phosphor oscilloscope, with clamp on current probes and passive voltage probes. (operated at 10MS/S)
4 input channels; 4 math channels; 8 measure channels; True Power cap
True Power via mean[Vinstant x linstant] gated over 2 AC cycles
Coil Heating via mean[Irms^2 x DCR] gated over 2 AC cycles

2each Extech MM560 Precision digital multimeter 50,000 count, 0.03% accuracy
DC dynamic resistance via V/I

Valhalla 2101 Integrating 4 quadrant True Power Meter
single channel Vrms, Irms, and True Power readout for cross check

DC RESISTANCE EVALUATION:

	DC current	DC voltage	resistance	temp degrees C	Resistance Calculator: temp C	R
copper temperature coefficient: 0.00393						
<u>Primary Circuit DC Resistance</u>	1.665	1.006	0.6042	21	25	0.6137
<u>Secondary Circuit DC Resistance:</u>	1.816	1.832	1.0088	21	21	1.0088
<u>Load DC Resistance</u>	0.354	8.886	25.1017	21	21	25.1017

ambient conditions:

21 degrees C 55 percent Relative Humidity

RUN NUMBER:

	1	2	3	4	5	6	7
Instrument	TEK	Valhalla					
Load	25ohm	25ohm					

HYSTERESIS EVALUATION:

Units:	1	2
UNLOADED PRIMARY VOLTAGE:	Vrms 10.300	10.160
UNLOADED PRIMARY CURRENT	Irms 3.083	3.060
NET HYSTERESIS POWER	watts True 4.556	4.600

LOADED EVALUATION

	1	2
PRIMARY VOLTAGE	Vrms 10.060	9.900
PRIMARY CURRENT	Irms 3.009	2.980
TOTAL INPUT POWER	watts True 8.533	8.900

OUTPUTS:

	1	2
Primary DC R	OHMS 0.6042	0.6042
Secondary DC R	OHMS 1.0088	1.0088
Load DC R	OHMS 25.1017	25.1017
SECONDARY VOLTAGE	Vrms 9.971	9.940
SECONDARY CURRENT	Irms 0.397	0.415
SECONDARY OUTPUT POWER	watts True 3.948	3.890

ADDITIONAL OUTPUTS:

	1	2
HYSTERESIS OF CORE	watts True 4.556	4.600
PRIMARY COIL HEATING	watts True 5.477	5.366
SECONDARY COIL HEATING	watts True 0.159	0.174
TOTAL ABSOLUTE OUTPUT	watts True 14.140	14.029

COP(absolute)

	1	2
EXCESS WATTS	watts True 5.607	5.129
COP(useful)	46.3%	43.7%

Load check:	check 3.956	4.323
(True Power at load vs load I^2R)	difference 0.008	0.433
Load check variance	percent 0.209%	10.019%
(load check verifies DC R values: if DC R is correct then variance is zero)		

Primary Power Factor	0.282	0.302
Secondary Power Factor	0.997	0.943

NOTE:

VALHALLA HAS ONLY 1 OR 2 SIGNIFICANT DIGIT RESOLUTION ON SOME SCALES. THIS ACCOUNTS FOR VALHALLA LOAD CHECK VARIANCE AT 10%

EITHER WAY, THIS IS UNASSAILABLE EVIDENCE OF O/U!!!


YOU CAN DISCOUNT THE HYST PWR COMPLETELY, AND STILL RETAIN O/U

(you cannot challenge the Joule heating values nor the input and output power, the only potential challenge is the core hyst/eddy power)

(since there must be some core loss, the actual COPabsolute must go up from the values below)

with Core Hyst removed:


112.3% **105.9%**
TEK **Valhalla**



Pri 40 .

V ↑

070



Pri 40